

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.:

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report
REPORT No: 24-026211 - Rev. 0

Client I.D.	Sample I.D.	Date Collected	Parameter	
			Lead	
			Units	mg/L
			R.L.	0.00002
			Limits	0.010
DWG	MAC			
			-	
T10-S	24-026211-11	2024-Aug-19	0.00026	
T7-S	24-026211-12	2024-Aug-19	0.00003	
B4-S	24-026211-13	2024-Aug-19	0.00015	
B15-F	24-026211-14	2024-Aug-19	0.00043	
B13-F	24-026211-15	2024-Aug-19	0.00018	
T10-F	24-026211-16	2024-Aug-19	0.00011	
T7-F	24-026211-17	2024-Aug-19	0.00011	
B4-F	24-026211-18	2024-Aug-19	0.00009	
F14-S	24-026211-19	2024-Aug-22	0.00003	
F11-S	24-026211-20	2024-Aug-22	0.00019	
F5-S	24-026211-21	2024-Aug-22	0.00042	
T9-S	24-026211-22	2024-Aug-22	0.04	
F14-F	24-026211-23	2024-Aug-22	0.00469	
F11-F	24-026211-24	2024-Aug-22	0.00020	
F5-F	24-026211-25	2024-Aug-22	0.00038	
T9-F	24-026211-26	2024-Aug-22	0.00023	
B14-S	24-026211-27	2024-Aug-21	0.00006	
B11-S	24-026211-28	2024-Aug-21	0.00028	
T6-S	24-026211-29	2024-Aug-21	0.00007	
T2-S	24-026211-30	2024-Aug-21	0.00006	
F4-S	24-026211-31	2024-Aug-21	0.00027	



Lorina Merko
Laboratory Manager

CADUCEON Environmental Laboratories Certificate of Analysis

Client I.D.	Sample I.D.	Date Collected	Parameter
			Lead
			Units
			mg/L
			R.L.
			0.00002
			Limits
			0.010
			DWG
			MAC
Client I.D.	Sample I.D.	Date Collected	-
B14-F	24-026211-32	2024-Aug-21	0.00870
B11-F	24-026211-33	2024-Aug-21	0.00022
T6-F	24-026211-34	2024-Aug-21	0.00021
T2-F	24-026211-35	2024-Aug-21	0.05 7
F4-F	24-026211-36	2024-Aug-21	0.00022
T1-S	24-026211-37	2024-Aug-23	0.00027
T12-S	24-026211-38	2024-Aug-23	0.00188
B3-S	24-026211-39	2024-Aug-23	0.00003
F3-S	24-026211-40	2024-Aug-23	0.00004
T1-F	24-026211-41	2024-Aug-23	0.00243
T12-F	24-026211-42	2024-Aug-23	0.00064
B3-F	24-026211-43	2024-Aug-23	0.00006
F3-F	24-026211-44	2024-Aug-23	0.00026

DWG - Drinking Water Guidelines

Summary of Exceedances		
Maximum Acceptable Concentration		
T9-S	Found Value	Limit
Lead	0.0491	0.010
T2-F	Found Value	Limit
Lead	0.0527	0.010



Lorina Merko
Laboratory Manager